


Customer :

LaBour/Taber

2005 Dr Martin Luther King Jr Street Indianapolis, In 46207-7026

| | | | |
|--|---|---|--------------|
| Project : | | Contact : | |
| Quote No. : US-2222-17 | Page No. : 1 | Phone : | Fax : |
| | | Date : Wednesday, April 16, 2003 | |
| Pump Model: LaBour - 1.5x3-6 STP LVB | Nom. Speed: 1750 RPM, 60 Hz Electric | Duty Flow : | US gpm |
| Type: LVB - ANSI Standard End Suction | Impeller Dia.: 6.06/4 inch | Duty Head : | ft |
| | Temperature: 68 °F | Efficiency : | % |
| | Viscosity: 1.009 cP | Power Required : | hp |
| Curve No.: 8196-003 | Sp. Gravity: 1.000 | NPSH Required : | ft |
| Impeller No.: | Fluid: Water | Peak Power: | 1.56 hp |
| Item : 1 | | Closed Valve Pressure | 37.638 ft |
| Your Ref.: | Tolerance : Hyd Inst-Peerless Std | | |



Comments:

Performance curve represents typical performance. See Standard Hydraulic Performance document in the selective printing area of RAPID for testing tolerances & contractual guarantees.



Customer :

LaBour/Taber

2005 Dr Martin Luther King Jr Street Indianapolis, In 46207-7026

| | | | |
|-------------------------------|---------------------|---|--------------|
| Project : | | Contact : | |
| Quote No. : US-2222-17 | Page No. : 1 | Phone : | Fax : |
| | | Date : Wednesday, April 16, 2003 | |

| | | | |
|--|---|------------------------------|------------|
| Pump Model: LaBour - 1.5x3-6 STP LVB | Nom. Speed: 3550 RPM, 60 Hz Electric | Duty Flow : | US gpm |
| Type: LVB - ANSI Standard End Suction | Impeller Dia.: 6.06/4 inch | Duty Head : | ft |
| | Temperature: 68 °F | Efficiency : | % |
| | Viscosity: 1.009 cP | Power Required : | hp |
| Curve No.: 8196-004 | Sp. Gravity: 1.000 | NPSH Required : | ft |
| Impeller No.: | Fluid: Water | Peak Power: | 11.56 hp |
| Item : 1 | | Closed Valve Pressure | 154.889 ft |
| Your Ref.: | Tolerance : Hyd Inst-Peerless Std | | |

